

# WATER

14-09-2007

## PERFORMANCE GUARANTEE

Water Ltd. (Denmark) hereby guarantee, that the UV systems supplied to Environmental Treatment Systems Ltd. (ETS) (England), when installed within the final settlement tank effluent tee:

**that the discharged effluent will contain  
less than 1000 faecal coliforms and e. coli per 100 ml.**

This guarantee is valid during the entire period of 1 year after installation of a new UV-Lamp.

Providing that the influent water is domestic waste water, and that the following parameters are not exceeded in the discharged water from the ETS systems:

BOD (Max) 25 mg/l  
SS (Max) 25 mg/l  
P (Max) 1 mg/l  
N (tot) (Max) 40 mg/l

And that the discharged water flow is lower than 50 litre per hour per Watt UV-Lamp installed.

(This means that 2 cubic meter water discharged from the ETS system per hour is the maximum amount of water for a 40 Watt UV-Lamp Installation supplied by Water Ltd.).

Yours sincerely

Richard Martin.

[www.water.dk](http://www.water.dk)

Water Ltd. Jægersborgvej 7 DK-4733 Tappernøje Denmark  
Tel: + 45 2992 7755 E-mail [water@water.dk](mailto:water@water.dk) CVR no. DK 29 40 77 11